



March 22, 2019

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

**Roberts Paideia
Resample**

Dear Cynthia:

Samples for one location were collected in a second resample round of lead analyses for Roberts Paideia Academy. Greater Cincinnati Water Works (GCWW) analyzed the samples and compared the results.

School Sample Results

The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead. Results are shown below.

Cincinnati Public Schools - Roberts Paideia Academy Lead Testing Results-Resamples					
SAMPLE	Initial 1st Draw sample Date 3/1/18 Lead, ppb	Changes made after first round of sampling	1st Draw sample Date 1/11/19 Lead, ppb	30 second flush sample Date 1/11/19 Lead, ppb	60 second flush sample Date 1/11/19 Lead, ppb
RPA-FL1-1106FRONTDESK-SINK-RPA20	96.5	Cleaned aerator; flushed the line	<1	<1	<1

Changes made and Next Steps

After conducting a resample round in September 2018, remediations were done, and resamples were collected in a second resample round in January 2019 at one location.


For this location, RPA20, the aerator was cleaned and the lines were flushed with ample water before resampling. This greatly reduced the lead levels at this location; no further action is suggested.

Your work and changes in the school continue to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy while attending your school.



Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 if you have any questions.

Sincerely,



Cathy B. Bailey

Director/Greater Cincinnati Water Works

Cc: Melba Moore, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Rashmi Aparajit, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works